



401.1.1.101

401.1.1.101

5'-1"

30'-0 1/2"

29'-10"

6'-3"

6'-3"

29'-10"

B.2

C

C.9

D

D.3

3

4

4.3

5

5.3

2000 kW EMERGENCY GENERATOR
TOP OF GENERATOR
13'-8"

SINGLE DOOR THIS
COMPLY WITH CODE
TO BE ADDED IN
UPCOMING BULLETIN

FOR AND FOR PIPING DOWN TO
GENERATORS SEE 92M FL. DMGS.
(TYP. 4 LOCATIONS)

EL. RACK
T=11'-0"
B=9'-9"
ABV 1492'-10"

18" GEN. EXHAUST UP

18" GEN. EXHAUST UP

18" GEN. EXHAUST UP

18" GEN. EXHAUST UP

EL. RACK
T=10'-4"
B=9'-3"
ABV 1492'-10"

EL. RACK
T=10'-3"
B=9'-3"
ABV 1492'-10"

EL. RACK
T=10'-3"
B=9'-3"
ABV 1507'-0"

EXIT STAIR B
91-007 1000

4,000 A C/B
(TYP OF 4)

DN